

BRE**Loss Prevention Certification Board**

Garston, Watford, WD25 9XX

Tel: 01923 664100 Fax: 01923 664603 Email: stevensp@bre.co.uk Web: www.brecertification.co.uk

Mr Alastair Archibald
Airsense Technology Ltd
71 Knowl Piece
Wilbury Way
Hertfordshire
SG4 0TY

Our reference pas1798 - Airsense -
Micra 90 day approval.doc

Your reference

18th November 2004

Dear Mr Archibald

LPCB APPROVAL MICRA 25; CP106387

This letter grants LPCB approval of the Airsense Technology Limited aspirating detection device listed below, for a period of 90 days, or until the date of the certificate issue.

LPCB reference numbers have been allocated to the products as follows:

Description	LPCB Ref. No
Micra 25 high sensitivity aspirating smoke detector with pipe exhaust docking station	404b/05

Notes:

1. For compliance with CEA 4022, the detector shall be supplied with power from a power supply complying with EN54-4.
2. The approval of the detector is conditional upon the following requirements:
 - Design, installation and commissioning are performed in accordance with the system design manual and instructions, by installers accredited by the manufacturer.
 - Each area is protected by a minimum of 2 holes.
 - Installations are to be installed with a maximum of 9 sampling holes with 1 'end cap' hole.
3. The detector has been assessed for compliance with clause 5.15 Fire sensitivity (room protection).

The performance of this device has been found to meet the requirements of CEA 4022: 1999-12.

Approval of the product is granted subject to the following conditions:

1. All products supplied between the date of this letter and the issue of the certificates shall be traceable to individual site installations.
2. The client takes full responsibility for any subsequent recall.
3. All approved devices shall be marked with the appropriate LPCB reference number as detailed above.
4. This approval is subject to a successful review of the technical evaluation file. If significant issues are raised during this review, LPCB reserve the right to withdraw this product certification.




 BRE

5. This product shall be subject to a product audit, to be performed within 3 months of the issue date of the Certificate. The audit shall be performed at the expense of Airsense Technology Limited. If significant problems are identified within this audit LPCB reserve the right to withdraw product certification.


If you have any queries please do not hesitate to contact me.

Yours sincerely



E Mattie-Suleiman
Technical Manager

Reviewed by



Richard Phillips
Technical Director

